


Wiring Woertz 45323T /PN

PLC is looking for NPN (or dry contact inputs)



If the PLC wants an NPN signal and itself doesn't have an internal pull-up resistor, then you have to put one externally! Try with 2.2kOhm/0.6W or if that doesn't work, with 1kOhm/1W

Best regards, Dan / electrobrains